

WISCONSIN PUBLIC SERVICE

P.O. Box 1231 Madison, WI 53701-1231 608-252-7000

life enhancing energy

2001 MAY - 1 A 11: 10

April 30, 2001

RECEIVED

RECEIVED

Madison Gas and Electric Compa

MAY 0 1 2001

Electric Division

Mr. James D. Loock Chief Engineer, Electric Division Public Service Commission of Wisconsin 610 North Whitney Way Post Office Box 7854 Madison, Wisconsin 53707-7854

Subject: PSC 113.0607 - Appropriate Inspection and Maintenance System Reliability -Operating Performance Statistics

Dear Mr. Loock:

To satisfy the requirements of the service rule referenced above, enclosed is MGE's Operating Performance Statistics for units nameplate rated at 50 MWs or more. The West Marinette Combustion Turbine is the only unit owned and operated by MGE that is nameplate rated larger than 50 MWs.

I believe this information satisfies the requirements of PSC 113.0607, paragraph six (6), but if you have any questions or require additional information, please contact me at your earliest convenience.

Sincerely,

Steven C. Dietrich, P.E.

Director - Blount Maintenance and Stores

dsh

Enclosure

				Scheduled Outage Factor		0.00			
	:	1		Forced Outage Rate		35.34			
1				Fuel Consumed Total MMBTU's				(0)	
:		-		Cap. Factor		5.94	:	s)] × 100(%	
	ties	nance Plai		Heat Rate Btu/KWh			:	Service Hours	
2000	Generating Facilities	WPSC Preventive Maintenance Plan	Attachment A	Net Generation MWh		31,417		utage Hours + eriod Hours) x	
	Gener	SC Preven	At	Net Winter Capacity MW		106		rs/ (Forced O tage Hours/P	
		W	1	Net Summer Capacity		78		Outage Hou	
					ecunology lype	24 Combustion furbine	oligina ilonengilloo	Definitions: Forced Outage Rate - [Forced Outage Hours/ (Forced Outage Hours + Service Hours)] x 100(%) Scheduled Outage Factor - (Scheduled Outage Hours/Period Hours) x 100(%)	
			:		Chit	7,	40	Force	
					Plant	West	Marinette	Definitions	

M34 Facility Monthly Operating Report December 2000

Operational Data
Opening readings were taken on 12/01/2000
Closing readings were taken on 1/01/2001

		June	July	Aug	gust	Sept	tember
Gross Generation Net Generation	kWh kWh	6,242,000 6,152,000		4,481,000 4,398,000	10,394,000 10,308,000		2,388,000 2,318,000
Natural Gas Fuel	CCF	774,700		559,500	1,278,700		300,900
illate Fuel	Gal	0		0	0		0
Demineralized Water Consumed	Gal	0		0	0		0
Heat Rate	Btu/kWh	12693		12836	12516		13098
Cap. Factor (Nameplate)	%	10.44		7.25	34.17		3.99
Total Fired Hours	hrs	X		24.5	160.8		39
Peak Fired Hours	hrs	X		0	0		0
Gas Fired Hours	hrs	X		24.5	160.8		39
Fired Starts		Х		3	13		3
Emergency Trips		X		0	0		0

M34 Facility Monthly Operating Report December 2000

Operational Data
Opening readings were taken on 12/01/2000
Closing readings were taken on 1/01/2001

		October	November	December	YTD
Gross Generation	kWh	1.103.000	4,721,000	2,654,000	31.983.000
Net Generation	kWh	1,034,000	4,644,000	2,563,000	31,417,000
Natural Gas Fuel	CCF	92,200	590,500	358.600	3,955,100
.llate Fuel	Gal	40.037	2699	1705	44,441
Demineralized Water Consumed	Gal	17,186	1,356	0	18,542
Heat Rate	Btu/kWh	14,332*	12,897	14,195	
Cap. Factor (Nameplate)	%	1.78	7.89	4.29	7.50
Total Fired Hours	hrs	23.2	76.5	51.6	499.9
Peak Fired Hours	hrs	0	0	0	5.4
Gas Fired Hours	hrs	12.1	76	51.2	487.9
Fired Starts		26	8	14	80
Emergency Trips		6	0	0	6

M34 Facility Monthly Operating Report January 2001

Operational Data Opening readings were taken on 1/1/2001 Closing readings were taken on 2/1/2001

		January	YTD
Gross Generation	kWh	5,235,000	5,235,000
Net Generation	kWh	5,145,000	5,145,000
Natural Gas Fuel	CCF	361,100	361,100
Distillate Fuel	Gal	202,499	202,499
nineralized er Consumed	Gal	142,326	142,326
Heat Rate	Btu/kWh	12,506	12,506
Cap. Factor (Nameplate)	0/0	8.47	8.47
Total Fired Hours	hrs	73.1	73.1
Peak Fired Hours	hrs	0	()
Gas Fired Hours	hrs	42.0	42.0
Fired Starts		10	10
Emergency Trips		6	6

M34 Facility Monthly Operating Report February 2001

Operational Data
Opening readings were taken on 2/1/2001
Closing readings were taken on 3/1/2001

		January	February	YTD
Gross Generation	kWh	5,235,000	8,104,000	13,339,000
Net Generation	kWh	5,145,000	8,016,000	13,161,000
Natural Gas Fuel	CCF	361,100	1,003,200	1,364.300
Distillate Fuel	Gal	202,499	0	202,499
mineralized .ter Consumed	Gal	142,326	0	142,326
Heat Rate	Btu/kWh	12,506	12,615	12,572
Cap. Factor (Nameplate)	%	8.47	14.5	11.3
Total Fired Hours	hrs	73.1	117.8	190.9
Peak Fired Hours	hrs	0	1.0	1.0
Gas Fired Hours	hrs	42.0	117.8	159.8
Fired Starts		10	8	18
Emergency Trips		6	0	6

M34 Facility Monthly Operating Report

Operational Data		January	February	March	April	May	June	July	August	September		October November December	December	YTD
Gross Generation	KWH	5,235,000	8,104.000	9,242,000	0	0	0	. 0	0	0	0	0	0	22,581,000
Net Generation	HWX	5,145,000	8,016,000	9,154,000	0	0	0	0	0	0	0	0	0	22,315,000
Natural Gas Fuel	CCF	361,100	1,003,200	1,128,300	0	0	0	0	0	0	0	0	0	2,492,600
Distillate Fuel	GAL	202,499	0	0	0	0	0	0	0	0	9	0	0_	202,499
Demineralized Water Consumed	GAL	142,326	0	0	0	0	0	0	0	0	0	0	0	142,326
Heat Rate	вти/кwн	12,506	12,615	12,424	0	0	0	0	0	0	0	0	0	12,512
(Nameplate)	%	8.47	14.52	14.95	#DIV/0!	#DIV/0!	#DIV/01	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	13
Total Fired Hours	HRS	73.10	117.80	130.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	321
Peak Fired Hours	HRS	0.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Gas Fired Hours	HRS	42.00	117.80	130.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	290
Fired Starts		10	8	9	0	0	0	. 0	0	0	0	0	0_	27
Emergency Trips		თ	0	0	0	0	0	0	0	0	0	0	0	თ
Period Hours		744	672	744	0	0	0	0	0	0	0	0	<u> </u>	2,160
Opening Reading Taken on Closing Reading Taken on	en on	1/1/2001 2/1/2001	2/1/2001 3/1/2001	03/01/01 04/01/01	03/01/01	mm/dd/yyyy i mm/dd/yyyy i	mm/dd/yyyy mm/dd/yyyy	mm/dd/yyyy mm/dd/yyyy	mm/dd/yyyy mm/dd/yyyy	03/01/01 mm/dd/yyyy	mm/dd/yyyy mm/dd/yyyy	mm/dd/yyyy mm/dd/yyyy	mm/dd/yyyy mm/dd/yyyy	
Bruce Crocker	4/5/2001													

Eastern Hydro Supervisor